



ANALYTICAL SUMMARY REPORT

October 12, 2020

Town of Rolling Hills
38 S Badger Rd
Rolling Hills, WY 82637

Work Order: C20100142

Project Name: WY5600782

Energy Laboratories, Inc. Casper WY received the following 10 samples for Town of Rolling Hills on 10/5/2020 for analysis.

Lab ID	Client Sample ID	Collect Date	Receive Date	Matrix	Test
C20100142-001	39 S Badger Rd	09/30/20 4:32	10/05/20	Drinking Water	Metals by ICP/ICPMS, Drinking Water Metals pH check by the Laboratory FIRST Metals pH check by the Laboratory SECOND Metals Preparation by EPA 200.2
C20100142-002	40 Cougar Rd	09/29/20 7:30	10/05/20	Drinking Water	Same As Above
C20100142-003	38 S Badger	10/01/20 7:15	10/05/20	Drinking Water	Same As Above
C20100142-004	7 - 55 Ranch Rd	09/29/20 3:30	10/05/20	Drinking Water	Same As Above
C20100142-005	15 Rimrock Rd	09/29/20 6:00	10/05/20	Drinking Water	Same As Above
C20100142-006	7 S. Badger Rd	09/28/20 6:00	10/05/20	Drinking Water	Same As Above
C20100142-007	67 S Badger Rd	09/30/20 5:45	10/05/20	Drinking Water	Same As Above
C20100142-008	9 Lynx Rd	09/29/20 16:50	10/05/20	Drinking Water	Same As Above
C20100142-009	34 N Badger Rd	10/02/20 6:05	10/05/20	Drinking Water	Same As Above
C20100142-010	40 S Bobcat Rd	10/02/20 8:47	10/05/20	Drinking Water	Same As Above

The analyses presented in this report were performed by Energy Laboratories, Inc., 2393 Salt Creek Hwy., Casper, WY 82601, unless otherwise noted. Any exceptions or problems with the analyses are noted in the Laboratory Analytical Report, the QA/QC Summary Report, or the Case Narrative. Any issues encountered during sample receipt are documented in the Work Order Receipt Checklist.

The results as reported relate only to the item(s) submitted for testing. This report shall be used or copied only in its entirety. Energy Laboratories, Inc. is not responsible for the consequences arising from the use of a partial report.

If you have any questions regarding these test results, please contact your Project Manager .

Report Approved By:



LABORATORY ANALYTICAL REPORT

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Client Sample ID: 39 S Badger Rd

PWS #: WY5600782 **Name:** ROLLING HILLS, TOWN OF

Facility ID: DIST

SamplingPoint/Location: DIST / 39 S Badger Rd

Project ID: WY5600782

Collector's Name: Homeowner

Contact Phone #: (307) 436-2622

Compliance Sample: YES

Sample Type: RT

Lab ID: C20100142-001

Report Date: 10/12/20

Collection Date: 09/30/20 04:32

Date Received: 10/05/20

Matrix: Drinking Water

Federal ID#: WY00002

FRDS Analyses	Result	Units	Qual	RL	MCL/ QCL	Method	Analysis Date / By
METALS, TOTAL							
1022 Copper	0.01	mg/L		0.01	1.3	E200.8	10/08/20 07:18 / jcg
1030 Lead	ND	mg/L		0.001	0.015	E200.8	10/08/20 07:18 / jcg

Report RL - Analyte Reporting Limit

Definitions: QCL - Quality Control Limit

MCL - Maximum Contaminant Level

ND - Not detected at the Reporting Limit (RL)



LABORATORY ANALYTICAL REPORT

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Client Sample ID: 40 Cougar Rd

PWS #: WY5600782 **Name:** ROLLING HILLS, TOWN OF

Facility ID: DIST

SamplingPoint/Location: DIST / 40 Cougar Rd

Project ID: WY5600782

Collector's Name: Homeowner

Contact Phone #: (307) 436-2622

Compliance Sample: YES

Sample Type: RT

Lab ID: C20100142-002

Report Date: 10/12/20

Collection Date: 09/29/20 07:30

Date Received: 10/05/20

Matrix: Drinking Water

Federal ID#: WY00002

FRDS Analyses	Result	Units	Qual	RL	MCL/ QCL	Method	Analysis Date / By
METALS, TOTAL							
1022 Copper	0.01	mg/L		0.01	1.3	E200.8	10/08/20 07:23 / jcg
1030 Lead	ND	mg/L		0.001	0.015	E200.8	10/08/20 07:23 / jcg

Report RL - Analyte Reporting Limit

Definitions: QCL - Quality Control Limit

MCL - Maximum Contaminant Level

ND - Not detected at the Reporting Limit (RL)



LABORATORY ANALYTICAL REPORT

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Client Sample ID: 38 S Badger

PWS #: WY5600782 **Name:** ROLLING HILLS, TOWN OF

Facility ID: DIST

SamplingPoint/Location: DIST / 38 S Badger

Project ID: WY5600782

Collector's Name: Homeowner

Contact Phone #: (307) 436-2622

Compliance Sample: YES

Sample Type: RT

Lab ID: C20100142-003

Report Date: 10/12/20

Collection Date: 10/01/20 07:15

Date Received: 10/05/20

Matrix: Drinking Water

Federal ID#: WY00002

FRDS Analyses	Result	Units	Qual	RL	MCL/ QCL	Method	Analysis Date / By
METALS, TOTAL							
1022 Copper	0.04	mg/L		0.01	1.3	E200.8	10/08/20 07:27 / jcg
1030 Lead	0.002	mg/L		0.001	0.015	E200.8	10/08/20 07:27 / jcg

Report RL - Analyte Reporting Limit

Definitions: QCL - Quality Control Limit

MCL - Maximum Contaminant Level

ND - Not detected at the Reporting Limit (RL)



LABORATORY ANALYTICAL REPORT

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Client Sample ID: 7 - 55 Ranch Rd

PWS #: WY5600782 **Name:** ROLLING HILLS, TOWN OF

Facility ID: DIST

SamplingPoint/Location: DIST / 7 - 55 Ranch Rd

Project ID: WY5600782

Collector's Name: Homeowner

Contact Phone #: (307) 436-2622

Compliance Sample: YES

Sample Type: RT

Lab ID: C20100142-004

Report Date: 10/12/20

Collection Date: 09/29/20 03:30

Date Received: 10/05/20

Matrix: Drinking Water

Federal ID#: WY00002

FRDS Analyses	Result	Units	Qual	RL	MCL/ QCL	Method	Analysis Date / By
METALS, TOTAL							
1022 Copper	0.05	mg/L		0.01	1.3	E200.8	10/08/20 07:45 / jcg
1030 Lead	ND	mg/L		0.001	0.015	E200.8	10/08/20 07:45 / jcg

Report RL - Analyte Reporting Limit
Definitions: QCL - Quality Control Limit

MCL - Maximum Contaminant Level
ND - Not detected at the Reporting Limit (RL)



LABORATORY ANALYTICAL REPORT

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Client Sample ID: 15 Rimrock Rd

PWS #: WY5600782 **Name:** ROLLING HILLS, TOWN OF

Facility ID: DIST

SamplingPoint/Location: DIST / 15 Rimrock Rd

Project ID: WY5600782

Collector's Name: Homeowner

Contact Phone #: (307) 436-2622

Compliance Sample: YES

Sample Type: RT

Lab ID: C20100142-005

Report Date: 10/12/20

Collection Date: 09/29/20 06:00

Date Received: 10/05/20

Matrix: Drinking Water

Federal ID#: WY00002

FRDS Analyses	Result	Units	Qual	RL	MCL/ QCL	Method	Analysis Date / By
METALS, TOTAL							
1022 Copper	0.01	mg/L		0.01	1.3	E200.8	10/08/20 07:50 / jcg
1030 Lead	ND	mg/L		0.001	0.015	E200.8	10/08/20 07:50 / jcg

Report RL - Analyte Reporting Limit
Definitions: QCL - Quality Control Limit

MCL - Maximum Contaminant Level
ND - Not detected at the Reporting Limit (RL)



LABORATORY ANALYTICAL REPORT

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Client Sample ID: 7 S. Badger Rd

PWS #: WY5600782 **Name:** ROLLING HILLS, TOWN OF

Facility ID: DIST

SamplingPoint/Location: DIST / 7 S. Badger Rd

Project ID: WY5600782

Collector's Name: Homeowner

Contact Phone #: (307) 436-2622

Compliance Sample: YES

Sample Type: RT

Lab ID: C20100142-006

Report Date: 10/12/20

Collection Date: 09/28/20 06:00

Date Received: 10/05/20

Matrix: Drinking Water

Federal ID#: WY00002

FRDS Analyses	Result	Units	Qual	RL	MCL/ QCL	Method	Analysis Date / By
METALS, TOTAL							
1022 Copper	ND	mg/L		0.01	1.3	E200.8	10/08/20 07:54 / jcg
1030 Lead	ND	mg/L		0.001	0.015	E200.8	10/08/20 07:54 / jcg

Report RL - Analyte Reporting Limit
Definitions: QCL - Quality Control Limit

MCL - Maximum Contaminant Level
ND - Not detected at the Reporting Limit (RL)



LABORATORY ANALYTICAL REPORT

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Client Sample ID: 67 S Badger Rd

PWS #: WY5600782 **Name:** ROLLING HILLS, TOWN OF

Facility ID: DIST

SamplingPoint/Location: DIST / 67 S Badger Rd

Project ID: WY5600782

Collector's Name: Homeowner

Contact Phone #: (307) 436-2622

Compliance Sample: YES

Sample Type: RT

Lab ID: C20100142-007

Report Date: 10/12/20

Collection Date: 09/30/20 05:45

Date Received: 10/05/20

Matrix: Drinking Water

Federal ID#: WY00002

FRDS Analyses	Result	Units	Qual	RL	MCL/ QCL	Method	Analysis Date / By
METALS, TOTAL							
1022 Copper	0.05	mg/L		0.01	1.3	E200.8	10/08/20 07:59 / jcg
1030 Lead	ND	mg/L		0.001	0.015	E200.8	10/08/20 07:59 / jcg

Report RL - Analyte Reporting Limit

Definitions: QCL - Quality Control Limit

MCL - Maximum Contaminant Level

ND - Not detected at the Reporting Limit (RL)



LABORATORY ANALYTICAL REPORT

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Client Sample ID: 9 Lynx Rd

PWS #: WY5600782 **Name:** ROLLING HILLS, TOWN OF

Facility ID: DIST

SamplingPoint/Location: DIST / 9 Lynx Rd

Project ID: WY5600782

Collector's Name: Homeowner

Contact Phone #: (307) 436-2622

Compliance Sample: YES

Sample Type: RT

Lab ID: C20100142-008

Report Date: 10/12/20

Collection Date: 09/29/20 16:50

Date Received: 10/05/20

Matrix: Drinking Water

Federal ID#: WY00002

FRDS Analyses	Result	Units	Qual	RL	MCL/ QCL	Method	Analysis Date / By
METALS, TOTAL							
1022 Copper	0.02	mg/L		0.01	1.3	E200.8	10/08/20 08:22 / jcg
1030 Lead	0.002	mg/L		0.001	0.015	E200.8	10/08/20 08:22 / jcg

Report RL - Analyte Reporting Limit
Definitions: QCL - Quality Control Limit

MCL - Maximum Contaminant Level
ND - Not detected at the Reporting Limit (RL)



LABORATORY ANALYTICAL REPORT

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Client Sample ID: 34 N Badger Rd

PWS #: WY5600782 **Name:** ROLLING HILLS, TOWN OF

Facility ID: DIST

SamplingPoint/Location: DIST / 34 N Badger Rd

Project ID: WY5600782

Collector's Name: Homeowner

Contact Phone #: (307) 436-2622

Compliance Sample: YES

Sample Type: RT

Lab ID: C20100142-009

Report Date: 10/12/20

Collection Date: 10/02/20 06:05

Date Received: 10/05/20

Matrix: Drinking Water

Federal ID#: WY00002

FRDS Analyses	Result	Units	Qual	RL	MCL/ QCL	Method	Analysis Date / By
METALS, TOTAL							
1022 Copper	0.03	mg/L		0.01	1.3	E200.8	10/08/20 08:26 / jcg
1030 Lead	ND	mg/L		0.001	0.015	E200.8	10/08/20 08:26 / jcg

Report RL - Analyte Reporting Limit

Definitions: QCL - Quality Control Limit

MCL - Maximum Contaminant Level

ND - Not detected at the Reporting Limit (RL)



LABORATORY ANALYTICAL REPORT

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Client Sample ID: 40 S Bobcat Rd

PWS #: WY5600782 **Name:** ROLLING HILLS, TOWN OF

Facility ID: DIST

SamplingPoint/Location: DIST / 40 S Bobcat Rd

Project ID: WY5600782

Collector's Name: Homeowner

Contact Phone #: (307) 436-2622

Compliance Sample: YES

Sample Type: RT

Lab ID: C20100142-010

Report Date: 10/12/20

Collection Date: 10/02/20 08:47

Date Received: 10/05/20

Matrix: Drinking Water

Federal ID#: WY00002

FRDS Analyses	Result	Units	Qual	RL	MCL/ QCL	Method	Analysis Date / By
METALS, TOTAL							
1022 Copper	0.09	mg/L		0.01	1.3	E200.8	10/08/20 08:31 / jcg
1030 Lead	ND	mg/L		0.001	0.015	E200.8	10/08/20 08:31 / jcg

Report RL - Analyte Reporting Limit

Definitions: QCL - Quality Control Limit

MCL - Maximum Contaminant Level

ND - Not detected at the Reporting Limit (RL)



QA/QC Summary Report

Prepared by Casper, WY Branch

Client: Town of Rolling Hills

Work Order: C20100142

Report Date: 10/12/20

Analyte	Result	Units	RL	%REC	Low Limit	High Limit	RPD	RPDLimit	Qual
Method: E200.8					Analytical Run: ICPMS5-C_201007A				
Lab ID: QCS	Initial Calibration Verification Standard								10/07/20 20:14
Copper	0.0516	mg/L	0.0050	103	90	110			
Lead	0.0497	mg/L	0.0010	99	90	110			
Method: E200.8					Batch: R263258				
Lab ID: LRB	Method Blank								Run: ICPMS5-C_201007A 10/07/20 15:38
Copper	ND	mg/L	0.0010						
Lead	ND	mg/L	7E-05						
Lab ID: LFB	Laboratory Fortified Blank								Run: ICPMS5-C_201007A 10/07/20 15:42
Copper	0.0449	mg/L	0.0050	90	85	115			
Lead	0.0451	mg/L	0.0010	90	85	115			
Lab ID: C20100106-006BMS	Sample Matrix Spike								Run: ICPMS5-C_201007A 10/08/20 06:17
Copper	0.0445	mg/L	0.010	89	70	130			
Lead	0.0475	mg/L	0.0010	95	70	130			
Lab ID: C20100106-006BMSD	Sample Matrix Spike Duplicate								Run: ICPMS5-C_201007A 10/08/20 06:21
Copper	0.0433	mg/L	0.010	87	70	130	2.7	20	
Lead	0.0483	mg/L	0.0010	96	70	130	1.6	20	
Lab ID: C20100142-003AMS	Sample Matrix Spike								Run: ICPMS5-C_201007A 10/08/20 07:32
Copper	0.0811	mg/L	0.010	91	70	130			
Lead	0.0485	mg/L	0.0010	93	70	130			
Lab ID: C20100142-003AMSD	Sample Matrix Spike Duplicate								Run: ICPMS5-C_201007A 10/08/20 07:36
Copper	0.0839	mg/L	0.010	97	70	130	3.4	20	
Lead	0.0492	mg/L	0.0010	94	70	130	1.5	20	

Qualifiers:

RL - Analyte Reporting Limit

ND - Not detected at the Reporting Limit (RL)



Work Order Receipt Checklist

Town of Rolling Hills

C20100142

Login completed by: Alyson T. Degnan

Date Received: 10/5/2020

Reviewed by: Misty Stephens

Received by: tb1

Reviewed Date: 10/5/2020

Carrier name: Hand Del

Shipping container/cooler in good condition?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	Not Present <input type="checkbox"/>
Custody seals intact on all shipping container(s)/cooler(s)?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	Not Present <input type="checkbox"/>
Custody seals intact on all sample bottles?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	Not Present <input checked="" type="checkbox"/>
Chain of custody present?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
Chain of custody signed when relinquished and received?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
Chain of custody agrees with sample labels?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
Samples in proper container/bottle?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
Sample containers intact?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
Sufficient sample volume for indicated test?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
All samples received within holding time? (Exclude analyses that are considered field parameters such as pH, DO, Res Cl, Sulfite, Ferrous Iron, etc.)	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
Temp Blank received in all shipping container(s)/cooler(s)?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	Not Applicable <input checked="" type="checkbox"/>
Container/Temp Blank temperature:	3.0°C No Ice		
Water - VOA vials have zero headspace?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	No VOA vials submitted <input checked="" type="checkbox"/>
Water - pH acceptable upon receipt?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	Not Applicable <input type="checkbox"/>

Standard Reporting Procedures:

Lab measurement of analytes considered field parameters that require analysis within 15 minutes of sampling such as pH, Dissolved Oxygen and Residual Chlorine, are qualified as being analyzed outside of recommended holding time.

Solid/soil samples are reported on a wet weight basis (as received) unless specifically indicated. If moisture corrected, data units are typically noted as –dry. For agricultural and mining soil parameters/characteristics, all samples are dried and ground prior to sample analysis.

Radiochemical precision results represent a 2-sigma Total Measurement Uncertainty.

Contact and Corrective Action Comments:

Samples for Lead & Copper were preserved in the laboratory to pH <2 with 2 mL of nitric acid per liter upon receipt and within the EPA recommended 14 day holding time. In accordance with the Safe Drinking Water Act.



Trust our People. Trust our Data.

Chain of Custody & Analytical Request Record

www.energylab.com

Page ____ of ____

Account Information (Billing Information)

Company/Name	Town of Rolling Hills		
Contact			
Phone			
Mailing Address	38 S. Badger Rd.		
City, State, Zip	Rolling Hills, WY 82637		
Email			
Receive Invoice	<input type="checkbox"/> Hard Copy	<input type="checkbox"/> Email	Receive Report
Purchase Order	Quote		<input type="checkbox"/> Hard Copy <input type="checkbox"/> Email
		Bottle Order	

Report Information (If different than Account Information)

Company/Name			
Contact			
Phone			
Mailing Address			
City, State, Zip			
Email			
Receive Report	<input type="checkbox"/> Hard Copy	<input type="checkbox"/> Email	
Special Report/Formats:			
<input type="checkbox"/> LEVEL IV <input type="checkbox"/> NELAC <input type="checkbox"/> EDD/EDT (contact laboratory) <input type="checkbox"/> Other			

Comments

--	--

Project Information

Project Name, PWSID, Permit, etc.	WY 5600782C		
Sample Name	Perry	Sample Phone	307-258-1178
Sample Origin State	EPA/State Compliance <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
URANIUM MINING CLIENTS MUST indicate sample type.			
<input type="checkbox"/> NOT Source or Byproduct Material			
<input type="checkbox"/> Source/Processed Ore (Ground or Refined) **CALL BEFORE SENDING			
<input type="checkbox"/> 11e.(2) Byproduct Material (Can ONLY be Submitted to ELJ Casper Location)			

Matrix Codes

- A - Air
- W - Water
- S - Solids
- V - Vegetation
- B - Bioassay
- O - Other
- DW - Drinking Water

Analysis Requested

Sample Identification (Name, Location, Interval, etc.)	Collection		Number of Containers	Matrix (See Codes Above)	Analysis Requested										Signature RUSH TAT
	Date	Time													
1 39 S. Badger Rd	9/30/2006	4:32AM	1	W	X										
2 40 Cougar Rd	9/29/2006	7:30AM	1	W	X										
3 38 S. Badger Rd	10/1/2006	7:15AM	1	W	X										
4 7-55 Ranch Rd	9/29/2006	3:30AM	1	W	X										
5 15 Rimrock Rd	9/29/2006	6:00AM	1	W	X										
6 7 S. Badger Rd	9/28/2006	6:00AM	1	W	X										
7 607 S. Badger Rd	9/28/2006	5:45AM	1	W	X										
8 9 Lynx Rd	9/29/2006	4:50AM	1	W	X										
9 34 N. Badger Rd	10/2/2006	10:05AM	1	W	X										
10 40 S. Badger Rd	10/2/2006	8:47AM	1	W	X										

See Attached

All turnaround times are standard unless marked as RUSH.
Energy Laboratories MUST be contacted prior to RUSH sample submittal for charges and scheduling - See Instructions Page

Custody Record MUST be signed	Relinquished by (print)	Date/Time	Signature	Received by (print)	Date/Time	Signature
	Perry N. Elder	10/3/2006	9:00AM	Rolling Hills	10/3/2006	9:00AM

Shipped By	Cooler ID(s)	Custody Seal	Intact	Receipt Temp	Temp Blank	On Ice	CC	Cash	Check	Amount	Receipt Number (cashcheck only)
Hand		Y <input checked="" type="checkbox"/> N <input type="checkbox"/> C <input type="checkbox"/> B <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	3.0 °C	<input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/> N <input type="checkbox"/>					

In certain circumstances, samples submitted to Energy Laboratories, Inc. may be subcontracted to other certified laboratories in order to complete the analysis requested. This serves as notice of this possibility. All subcontracted data will be clearly notated on your analytical report.

C20100142

Suggested Directions for Homeowner Tap Sample Collection Procedures
Revised Version: May 2019

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through a collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you, the customer, to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacement has been done in the home since the previous sampling event, note this information on the label as provided. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the same location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call Perry at 258-1178 if you have any questions regarding these instructions.

Public Water Systems must retain these signed records for a minimum of 12 years. Please include one copy of this form with your Consumer Notice certification to the EPA.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>10:00 pm</u>	Date <u>9/29/20</u>	
Sample was collected:	Time <u>4:32 A.M.</u>	Date <u>9/30/20</u>	
Street Address:	<u>39 S. Badger</u>		
Sample Location & faucet (e.g. Bathroom sink):	<u>Kitchen sink</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Printed Name	<u>Donna Weaver</u>		
Signature	<u>Donna Weaver</u>	Date	<u>9/30/20</u>

C20100142

Suggested Directions for Homeowner Tap Sample Collection Procedures
Revised Version: May 2019

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through a collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you, the customer, to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacement has been done in the home since the previous sampling event, note this information on the label as provided. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the same location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call Perry at 258-1178 if you have any questions regarding these instructions.

Public Water Systems must retain these signed records for a minimum of 12 years. Please include one copy of this form with your Consumer Notice certification to the EPA.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>8pm 9/28/20</u>	Date <u>9/28/2020</u>	
Sample was collected:	Time <u>730 Am</u>	Date <u>9/29/2020</u>	
Street Address:	<u>40 Cougar</u>		
Sample Location & faucet (e.g. Bathroom sink):	<u>Kitchen faucet</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Printed Name	<u>Jody E. HLO</u>		
Signature	<u>Jody E. HLO</u>	Date	<u>9/29/2020</u>

C20100142

Suggested Directions for Homeowner Tap Sample Collection Procedures
Revised Version: May 2019

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through a collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you, the customer, to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacement has been done in the home since the previous sampling event, note this information on the label as provided. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the same location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call Perry at 258-1178 if you have any questions regarding these instructions.

Public Water Systems must retain these signed records for a minimum of 12 years. Please include one copy of this form with your Consumer Notice certification to the EPA.

TO BE COMPLETED BY RESIDENT

Water was last used: Time 3:30 PM Date 9/30/2020

Sample was collected: Time 7:15 AM Date 10/1/2020

Street Address: 38 S. BAKER

Sample Location & faucet (e.g. Bathroom sink): Kitchen Sink

I have read the above directions and have taken a tap sample in accordance with these directions.

Printed Name Perry N. Eller

Signature Perry N. Eller Date 10/1/2020

C2010042

Suggested Directions for Homeowner Tap Sample Collection Procedures
Revised Version: May 2019

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through a collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you, the customer, to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacement has been done in the home since the previous sampling event, note this information on the label as provided. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the same location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call Perry at 258-1178 if you have any questions regarding these instructions.

Public Water Systems must retain these signed records for a minimum of 12 years. Please include one copy of this form with your Consumer Notice certification to the EPA.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>7:30 pm</u>	Date <u>9-28-2020</u>	
Sample was collected:	Time <u>3:30 am</u>	Date <u>9-29-2020</u>	
Street Address:	<u>7 - 55 Ranch Road</u>		
Sample Location & faucet (e.g. Bathroom sink):	<u>Kitchen Sink</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Printed Name	<u>Twila Parks</u>		
Signature	<u>Twila Parks</u>	Date	<u>9-29-2020</u>

C20010142

Suggested Directions for Homeowner Tap Sample Collection Procedures
Revised Version: May 2019

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through a collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you, the customer, to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacement has been done in the home since the previous sampling event, note this information on the label as provided. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the same location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call Perry at 258-1178 if you have any questions regarding these instructions.

Public Water Systems must retain these signed records for a minimum of 12 years. Please include one copy of this form with your Consumer Notice certification to the EPA.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>9:30 PM</u>	Date <u>9/28/20</u>	
Sample was collected:	Time <u>6:21</u>	Date <u>9/29/20</u>	
Street Address:	<u>15 Rimrock</u>		
Sample Location & faucet (e.g. Bathroom sink):	<u>Kitchen Sink</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Printed Name	<u>Wesley Trott</u>		
Signature	<u>Wesley Trott</u>	Date	<u>9-29-20</u>

C2900142

Suggested Directions for Homeowner Tap Sample Collection Procedures
Revised Version: May 2019

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through a collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you, the customer, to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacement has been done in the home since the previous sampling event, note this information on the label as provided. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the same location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call Perry at 307-258-1176 if you have any questions regarding these instructions.

Public Water Systems must retain these signed records for a minimum of 12 years. Please include one copy of this form with your Consumer Notice certification to the EPA.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>10:00 AM</u>	Date <u>9-27-2020</u>	
Sample was collected:	Time <u>6:00 AM</u>	Date <u>9-28-2020</u>	
Street Address: <u>75 Badger</u>			
Sample Location & faucet (e.g. Bathroom sink): <u>Kitchen Sink</u>			
I have read the above directions and have taken a tap sample in accordance with these directions.			
Printed Name <u>Joseph Perko</u>			
Signature <u>[Signature]</u>		Date <u>9-28-2020</u>	

C20100142

Suggested Directions for Homeowner Tap Sample Collection Procedures
Revised Version: May 2019

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through a collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you, the customer, to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacement has been done in the home since the previous sampling event, note this information on the label as provided. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the same location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call Perry at 258-1178 if you have any questions regarding these instructions.

Public Water Systems must retain these signed records for a minimum of 12 years. Please include one copy of this form with your Consumer Notice certification to the EPA.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>11:00 AM</u>	Date <u>9-29-20</u>	
Sample was collected:	Time <u>5:45 AM</u>	Date <u>9-30-20</u>	
Street Address: <u>607 S. Badger</u>			
Sample Location & faucet (e.g. Bathroom Sink): <u>Kitchen Sink</u>			
I have read the above directions and have taken a tap sample in accordance with these directions.			
Printed Name <u>Russ Allen</u>			
Signature <u>Russ Allen</u>		Date <u>9-30-20</u>	

C20100142

Suggested Directions for Homeowner Tap Sample Collection Procedures
Revised Version: May 2019

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through a collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you, the customer, to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacement has been done in the home since the previous sampling event, note this information on the label as provided. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the same location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call Perry at 258-1178 if you have any questions regarding these instructions.

Public Water Systems must retain these signed records for a minimum of 12 years. Please include one copy of this form with your Consumer Notice certification to the EPA.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>10:00 Am</u>	Date <u>9-29-20</u>	
Sample was collected:	Time <u>4:50 pm</u>	Date <u>9-29-20</u>	
Street Address:	<u>9 LUNA</u>		
Sample Location & faucet (e.g. Bathroom sink):	<u>KITCHEN SINK</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Printed Name	<u>Nic Halvorsen</u>		
Signature	<u>[Signature]</u>	Date	<u>10/1/20</u>

C20100142

Suggested Directions for Homeowner Tap Sample Collection Procedures
Revised Version: May 2019

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through a collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you, the customer, to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacement has been done in the home since the previous sampling event, note this information on the label as provided. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the same location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call Perch at 258-1178 if you have any questions regarding these instructions.

Public Water Systems must retain these signed records for a minimum of 12 years. Please include one copy of this form with your Consumer Notice certification to the EPA.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>22:15</u>	Date <u>10-01-20</u>	
Sample was collected:	Time <u>6:05</u>	Date <u>10-02-20</u>	
Street Address: <u>34 N. Badger</u>			
Sample Location & faucet (e.g. Bathroom sink): <u>Kitchen Sink</u>			
I have read the above directions and have taken a tap sample in accordance with these directions.			
Printed Name <u>Ken Montgomery</u>			
Signature <u>[Signature]</u>		Date <u>10-2-20</u>	

C2010042

Suggested Directions for Homeowner Tap Sample Collection Procedures
Revised Version: May 2019

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through a collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you, the customer, to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacement has been done in the home since the previous sampling event, note this information on the label as provided. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the same location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call Perry at 258-1178 if you have any questions regarding these instructions.

Public Water Systems must retain these signed records for a minimum of 12 years. Please include one copy of this form with your Consumer Notice certification to the EPA.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>11:00 PM</u>	Date <u>10-1-2020</u>	
Sample was collected:	Time <u>8:47 AM</u>	Date <u>10-2-2020</u>	
Street Address: <u>40 S. Bobcat</u>			
Sample Location & faucet (e.g. Bathroom sink): <u>Kitchen Sink</u>			
I have read the above directions and have taken a tap sample in accordance with these directions.			
Printed Name <u>Isabelle Anderson</u>			
Signature <u>Isabelle Anderson</u>		Date <u>10-2-2020</u>	